


NSTX NBI In-Vessel Armor

Kelsey Tresemer

**NSTX Upgrade Project
Conceptual Design Review
LSB, B318
October 28-29, 2009**

College W&M
Colorado Sch Mines
Columbia U
CompX
General Atomics
INEL
Johns Hopkins U
LANL
LLNL
Lodestar
MIT
Nova Photonics
New York U
Old Dominion U
ORNL
PPPL
PSI
Princeton U
Purdue U
SNL
Think Tank, Inc.
UC Davis
UC Irvine
UCLA
UCSD
U Colorado
U Illinois
U Maryland
U Rochester
U Washington
U Wisconsin



Culham Sci Ctr
U St. Andrews
York U
Chubu U
Fukui U
Hiroshima U
Hyogo U
Kyoto U
Kyushu U
Kyushu Tokai U
NIFS
Niigata U
U Tokyo
JAEA
Hebrew U
Ioffe Inst
RRC Kurchatov Inst
TRINITI
KBSI
KAIST
POSTECH
ASIPP
ENEA, Frascati
CEA, Cadarache
IPP, Jülich
IPP, Garching
ASCR, Czech Rep
U Quebec



Armor Design: the Starting Point

- Previous FDR armor specifications
 - 1 Beamline, 3 Sources
 - Material: Isothermal graphite or ATJ
 - Existing cooling provided with 4 loops at 3.6 GPM, each
 - Conditions of Design:
 - Bakeout temp: 350 deg C
 - Worst Case “Fault”: 2.8 kW/cm² for 0.75 second
 - Thermal analysis results for “Fault”:
 - » Max temp = 1985.07 deg C
 - » Max tensile stress = 109.5 MPa
 - » **Our Baseline**

Transient Thermal Analysis Results



- Worst Case “Fault”: 2.8 kW/cm² for 0.75 second
- Max Temp: 1985.075 deg C





- This shows results of “Fault” conditions. Deemed permissible by previous FDR. Tile surface would be compromised, requiring inspection.

Time: 3.1 s

Time Step: 31 of 100

Maximum Value: 1985.07 deg C



Minimum Value: 101.186 deg C



Stress Analysis Results



- Worst Case “Fault”: 2.8 kW/cm² for 0.75 second
- Max Stress: 109.5 MPa





- This shows results of “Fault” conditions. Deemed permissible by previous FDR. Tile surface would be compromised, requiring inspection.


Load Case: 1 of 1

Maximum Value: 1.09483e+008 N/(m²)

Minimum Value: 4.38086e+006 N/(m²)




Current Beamline Placement



Armor Upgrade: Pulling Double-Duty

- 2 beamlines, 6 sources
 - » Tangency radii per GRD
- Use the existing armor array
 - Shift array counterclockwise to catch both sources




Evaluating Current Armor for Relocation & 6 Sources

- Both beamlines on armor
 - Look at Beam “Footprints”
 - Shows spread of beams, (x and y directions)
 - Compare with projected beam overlapping
 - Core Beam = 80% total beam power
 - Divergent Beam = 20% total beam power
 - Sufficient Clearance!
- Check overlapping heat loads
 - Ran test cases and compared against earlier “Fault” case
 - Design for this case, improve armor in other ways.
- Between-shot cooling required for pulse rate of 1200s
 - Original cooling lines designed for 900s

Existing Armor: Beam Footprints



New Armor: Applied Beam Heat Flux



New Armor Thermal Analysis

- Tested worst case (2 source, full power, overlapping) in ALGOR using a simple tile and various pulse lengths

Pulse length (s)	Heat Flux (W/m ²)	Max Temp (deg C)	Von mises (Mpa)
1	4.68E+07	4439.80	252.00
0.75	4.68E+07	4038.46	220.00
0.5	4.68E+07	3387.69	179.00
0.25	4.68E+07	2622.07	134.00

- The results dictate shot conditions. We shall take precautions not to allow a full-power “Fault” beyond 0.25 s
 - Provide a redundant plasma current interlock (beams run w/ plasma only)
 - In-armor thermocouples will be monitored to ensure between-shot cooling
 - Provide mid-plane material in backing plate in hot zones
 - Change armor tile material to CFC in hot zones
 - » ATJ sufficient in cooler regions
- “Fault” condition is unlikely, but if occurs, armor will survive, but will require physical inspection

Thermal Analysis for Between-Shot Cooling

- Worst case heat load on tile and backing plate
 - Ran test sample in ALGOR, simple shape
 - “Back of the envelope” Analysis
 - 3”x1” slice of armor (tile and backing plate), 3/8” cooling tube, 20 minutes between shots
 - Determined time constant for cooling
 - Preliminary results suggest cooling system adequate for in-between shot cooling
 - More tests needed to confirm. Numbers will be updated for FDR as analyses are completed

Thermal Analysis for Between-Shot Cooling





Time: 200 s

Time Step: 20 of 200


Maximum Value: 143.573 deg C

Minimum Value: 1.21787 deg C




New Armor: Vacuum Vessel Mounting

- Improving existing design for accessibility.
 - After move, armor is now nearly centered on bay H
 - Provides access to center mounts





New Armor: Vacuum Vessel Mounting

- Improving current design for accessibility.
 - Can access sides of backing plates through Bays I and G
 - Improves access to mid-plane mounts



New Armor: Vacuum Vessel Mounting & Loads

- Mounting scheme results in 16 mounting points for armor
 - Previous FDR disruptive loads on armor = 214000 lbs, radially
 - 13,375 lbs/mount
 - Assume 2X for upgrade
 - 26,750 lbs/mount
 - » These numbers need to be updated for PDR as analyses are completed



In Conclusion...

- We are going to....
 - Relocate existing armor array to accommodate all 6 sources
 - Armor tile material improvement to CFC for hot zones
 - Add backing plate supplementation
 - Provide engineering and administrative control to avoid “Fault”
 - Redundant IP interlock
 - Verify re-use of cooling system for upgrade
 - Improve armor mounting points for accessibility and increase in mechanical forces