


NSTX CSU Upgrade Overview

L. Dudek

**NSTX Upgrade Project
Conceptual Design Review
LSB, B318
October 28-29, 2009**



College W&M
Colorado Sch Mines
Columbia U
CompX
General Atomics
INEL
Johns Hopkins U
LANL
LLNL
Lodestar
MIT
Nova Photonics
New York U
Old Dominion U
ORNL
PPPL
PSI
Princeton U
Purdue U
SNL
Think Tank, Inc.
UC Davis
UC Irvine
UCLA
UCSD
U Colorado
U Illinois
U Maryland
U Rochester
U Washington
U Wisconsin

Culham Sci Ctr
U St. Andrews
York U
Chubu U
Fukui U
Hiroshima U
Hyogo U
Kyoto U
Kyushu U
Kyushu Tokai U
NIFS
Niigata U
U Tokyo
JAEA
Hebrew U
Ioffe Inst
RRC Kurchatov Inst
TRINITI
KBSI
KAIST
POSTECH
ASIPP
ENEA, Frascati
CEA, Cadarache
IPP, Jülich
IPP, Garching
ASCR, Czech Rep
U Quebec

Outline

- Introduction
- Scope
 - Central Core Mods
 - Structural Improvements
 - Electrical System Upgrades & Auxiliary Systems
- Peer Review Results
- Major Milestones
- Cost Estimates
- Risk
- Summary

Introduction

- Purpose

- To expand the NSTX operational space and thereby the physics basis for the next-step ST facilities
- To achieve higher levels of performance and pulse duration

- Requirements Summary

| | NSTX | NSTX-CSU |
|--|--------|----------|
| Plasma Major Radius [m] | 0.8540 | 0.9344 |
| Aspect Ratio | 1.266 | 1.500 |
| Plasma Current, I_P [MA] | 1.0 | 2.0 |
| Toroidal Field B_t [T] | 0.6 | 1.0 |
| Pulse Length, T_{pulse} [s] | 0.5 | 5.0 |
| Rep Rate $T_{\text{repetition}}$ [s] | 600 | 2400 |
| Center Stack Radius $R_{\text{centerstack}}$ [m] | 0.1849 | 0.3148 |
| Antenna Rad, R_{antenna} [m] | 1.5740 | 1.5740 |

NSTX Upgrades Scope

- Changes to the Central Core (Chrzanowski / Titus / Willard):
 - Toroidal Field (TF) inner leg bundle including flags, hubs, and flexible connectors
 - Ohmic Heating (OH) coil
 - Poloidal Field (PF) coils PF1A Upper, PF1A Lower, and PF1B
 - Microtherm thermal insulation
 - Center Stack Casing (CSC)
 - Plasma Facing Components (PFC) associated with CSC including the Inboard Divertor (IBD)
 - TF, OH, PF1A Upper (PF1AU), PF1A Lower (PF1AL), and PF1B Lower (PF1BL) coil electrical leads
 - CS and Supply piping for heating and cooling of CSC and IBD
- Structural Improvements (Dudek / Titus)
 - TF outer leg supports
 - PF coil supports
 - Pedestal which supports Center Stack Assembly from floor
 - Vacuum vessel if required (VV)
- Electrical Systems (Ramakrishnan)
 - Power Systems
 - CS Bakeout system
 - I&C systems
- Center Stack Diagnostics Sensors
- Auxiliary Systems
 - Cooling water system mods
 - CS and Supply piping for inboard gas injection


Changes to Central Core

- Design, Build and Install New CS Assembly including (Chrzanowski / Titus / Willard):

- New TF Hub Assembly
- New TF Stub and Flex Assemblies
- New Inner TF Bundle
- New Ohmic Heating Coil
- New Inconel Casing & Insulation
- New PFC Tiles
- New Poloidal Field 1a, b & c Coils
- New Ceramic Break


- R&D Activities to support above work

- TF electrical joint testing
- OH braze joint testing
- Stir Welding Tests



Structural Improvements Required

- Design Build and Install (Mangra / Dudek / Titus):
 - Reinforcement to existing coil structures to handle higher magnetic loads
 - Umbrella Structure
 - Outer TF Legs & Vacuum Vessel
 - Outer PF Coil
- Vacuum Vessel reinforcement may be necessary in localized areas (eg Passive Plate supports)



Electrical System Upgrades & Diagnostics

- Power Feed Upgrades (Ramakrishnan)
 - Upgrade TF power supply to support full field capability of ~1T. (At ~1T, ~2.5s flattop every 20 min and up to ~5 s every 40 min)
 - Existing cables will be reconnected for TF use. Thus there will be a total of 8 cables per pole for TF.
- Replace Centerstack Diagnostics
 - Rogowski Coils
 - Mirnov Coils
 - Flux Loops
 - Langmuir Probes
 - Thermocouples

Auxiliary Systems

- Gas Injection Systems

- Relocate existing center stack gas injection system to the new center stack

- Coil Cooling water modifications


- Increase in cooling water pressure by upgrading the pump for the OH coil to provide 600 psig (up from 400 psig)
- Upgrade the existing cooling water system to cool the outer TF coil legs separately from the inner

Peer Review

- A peer review of this design was held in mid August
- The reviewers included engineers from outside the lab
- Presentations included technical details on the analysis and the design concept
- At this review 40 Chits were generated and have been dispositioned
 - Most of the chits were written in the area of analysis recommendations and TF Inner to outer joint design (Willard)
 - Project has responded to these chits and the closeout is being tracked
 - There were no “show stoppers”

Major Milestones for Center Stack Upgrade

Center Stack Upgrade




Cost Estimates

- Cost estimates were generated by the Job Managers with input from engineers closest to the work
- Estimates are conservative
- Depending on the work estimated, they are based on
 - Previous NSTX construction
 - Quotes from Vendors or suppliers
 - Engineering Judgement
 - Published cost data (eg RS Means)
- Additional detail to be presented by R. Strykowski

Centerstack Upgrade Risks at CD-0

- Risk: The ability to find a cost effective TF Joint that works at higher fields.
 - The selected design has been verified through analysis to be far superior to the existing design for current capacity and liftoff (Willard presentation)
- Risk: Little room to re-enforce outer TF Legs and Umbrella Structure to handle higher loads.
 - The original concept of a diamond brace has evolved to a “radius rod concept”
 - Uses space utilized by existing support to transfer the loads back to the VV



Centerstack Upgrade Risks at CD-1

- The latest Risk Registry now has 34 risks identified
 - Vendor Performance (9)
 - Coil Fabrication (8)
 - Installation Difficulty (7)
 - Design error (4)
 - Analysis (3)
 - Other (3)
- Risk: OTF and PF Support Installation Difficulty
 - Design is being tailored to improve installation
 - Modular
 - Utilize space occupied by existing supports
 - Careful planning
 - Coordinate carefully with NB upgrade
 - Methodical removal of existing equipment

Summary

- The upgrade requirements are challenging but a conservative conceptual design is being presented
- The design is well defined and is ready to proceed to the preliminary design level
- The upgraded TF joint, which was problematic with the original design, has evolved into a robust design with major improvement in margin
- The cost estimates are based on the conservative design which is being presented