


# Analysis and Qualification Documentation

## The NSTX Upgrade Team

Presented By Peter H. Titus

**NSTX Center Stack Upgrade  
Peer Review  
LSB B318  
May 18, 2011**



Columbia U  
CompX  
General Atomics  
FIU  
INL  
Johns Hopkins U  
LANL  
LLNL  
Lodestar  
MIT  
Nova Photonics  
New York U  
ORNL  
PPPL  
Princeton U  
Purdue U  
SNL  
Think Tank, Inc.  
UC Davis  
UC Irvine  
UCLA  
UCSD  
U Colorado  
U Illinois  
U Maryland  
U Rochester  
U Washington  
U Wisconsin

Culham Sci Ctr  
U St. Andrews  
York U  
Chubu U  
Fukui U  
Hiroshima U  
Hyogo U  
Kyoto U  
Kyushu U  
Kyushu Tokai U  
NIFS  
Niigata U  
U Tokyo  
JAEA  
Hebrew U  
Ioffe Inst  
RRC Kurchatov Inst  
TRINITY  
NFRI  
KAIST  
POSTECH  
ASIPP  
ENEA, Frascati  
CEA, Cadarache  
IPP, Jülich  
IPP, Garching  
ASCR, Czech Rep

## NSTX CSU Calculation Index

WBS	Calc #	Calc Title	Preparer
1.1.0	NSTXU-CALC-132-03-00	Torque Egns for Design Point	Woolley
1.1.1	NSTXU-CALC-10-01-02	Global Model	P. Titus
1.1.1	NSTXU-CALC-10-02-00	Seismic Analysis	P. Titus
1.1.1	<i>NSTXU-CALC-11-01-00</i>	Heat Balance	A. Brooks
1.1.1	<i>NSTXU-CALC-11-02-00</i>	General Tile Program	J. Boales
1.1.1	<i>NSTXU-CALC-11-03-00</i>	Final Tile Stress Analysis (ATJ Tiles)	A. Brooks
1.1.1	<i>NSTXU-CALC-11-04-00</i>	Fastener Analysis	A. Brooks
1.1.1	NSTXU-CALC-12-01-01	Update of Analysis of Vacuum Vessel & Passive Plates	P. Titus
1.1.1	<i>NSTXU-CALC-12-03-00</i>	OPERA 2D Disruption Analyses	Hatcher
1.1.2	<i>NSTXU-CALC-12-02-00</i>	Dome/PF Rib Stresses	P. Titus
1.1.2	<i>NSTXU-CALC-12-04-00</i>	PF2 / PF3 Bolting, Bracket, and weld Stress	P. Titus
1.1.2	<i>NSTXU-CALC-12-05-00</i>	PF4 and PF5 Support Analysis	P. Titus
1.1.2	<i>NSTXU-CALC-12-06-00</i>	Aluminum Block (To Be Revised by Pete T.)	P. Titus
1.1.2	<i>NSTXU-CALC-12-07-00</i>	Umbrella Reinforcement Details	P. Titus
1.1.2	<i>NSTXU-CALC-12-08-00</i>	Lid/Spoke Assembly, Upper and Lower	P. Titus/Smith
1.1.2	<i>NSTXU-CALC-12-09-00</i>	Pedestal Analysis	P. Titus/Smith

1.1.3	NSTXU-CALC-133-03-00	Center Stack Casing Disruption Inductive and Halo Current Loads	P. Titus
1.1.3	NSTXU-CALC-133-04-00	OH Preload System and Belleville Spring Design ✓	Peter Rogoff
1.1.3	<i>NSTXU-CALC-133-05-00</i>	CS Casing Halo Ind and Res Cur	A. Brooks
1.1.3	<i>NSTXU-CALC-133-06-00</i>	OH Coolant Hole Optimization	A. Zolfaghari
1.1.3	<i>NSTXU-CALC-133-07-00</i>	OH Coax Lead Analysis	M. Mardenfeld
1.1.3	<i>NSTXU-CALC-133-08-00</i>	OH Stress Analyses	A. Zolfaghari
1.1.3	<i>NSTXU-CALC-133-09-00</i>	OH Fatigue and Fracture Mechanics ✓	P. Titus
1.1.3	<i>NSTXU-CALC-133-10-00</i>	Center Stack Casing Bellows	Peter Rogoff
1.1.3	<i>NSTXU-CALC-133-11-00</i>	OH & PF1 Electromagnetic Stability Analysis	P. Titus/Zolfaghari
1.1.4	<i>NSTXU-CALC-133-12-00</i>	Centerstack Manufacturing Fixtures	

1.1.2	NSTXU-CALC-132-04-00	Analysis of TF Outer Leg	Han Zhang
1.1.2	<i>NSTXU-CALC-132-09-00</i>	Analysis of Knuckle Clevis	P. Titus
1.1.2	<i>NSTXU-CALC-132-11-00</i>	Ring Bolted Joint	Peter Rogoff
1.1.3	NSTXU-CALC-131-01-00	Analysis of CSU Poloidal Field Coils	Woolley
1.1.3	NSTXU-CALC-131-02-00	Poloidal Magnetic Quantities for the Feb 2010 Provisional Design	Woolley
1.1.3	NSTXU-CALC-131-03-00	Poloidal Magnetic Quantities for the May 2010 Design Point	Woolley
1.1.3	NSTXU-CALC-132-05-00	Coupled EM-Thermal Analysis	Han Zhang
1.1.3	NSTXU-CALC-132-06-00	TF Flex Joint and Bundle Stub	T. Willard
1.1.3	NSTXU-CALC-132-07-00	Maximum Torsional Shear Stress	P. Titus
1.1.3	NSTXU-CALC-132-08-00	Determination of shear Forces Between the TF conductors and Insulation and the G-10 Insulating Crown.	A. Zolfaghari
1.1.3	<i>NSTXU-CALC-132-10-00</i>	TF Cool-down using FCOOL	A. Zolfaghari
1.1.3	NSTXU-CALC-133-01-01	Structural Analysis of the PF1 Coils, leads and Supports, Rev 1	L. Myatt
1.1.3	NSTXU-CALC-133-02-00	Thermal Stresses on OH-TF Coils	S. Avasarala



1.2.3	<i>NSTXU-CALC-40-01-00</i>	Diagnostics Review and Database	J. Boales
1.2.4	<i>NSTXU-CALC-24-01-00</i>	Vessel Port Re-Work for NB and Thompson Scattering Port	T. Willard
1.2.4	<i>NSTXU-CALC-24-02-00</i>	Armor Plate Backing Plate	L. Bryant
1.2.4	<i>NSTXU-CALC-24-03-00</i>	HHFW Antenna (needs to be modified for upgrade loads)	Han Zhang/Ellis
1.2.4	<i>NSTXU-CALC-24-04-00</i>	Magnetic Shielding Calculation	L. Bryant
1.5.2	<i>NSTXU-CALC-13-03-01</i>	DCPS Force Influence Coefficients	Hatcher
1.5.2	<i>NSTXU-CALC-13-05-00</i>	DCPS Moment Influence Coefficients	Woolley/Titus
1.5.5	<i>NSTXU-CALC-55-01-00</i>	Bus Bar Analysis	A. Khodak

# Available Documentation:

## 47 Calculations Total

NSTXU Calculation Web page  
( [http://nstx-upgrade.pppl.gov/Engineering/Calculations/index\\_Calcs.htm](http://nstx-upgrade.pppl.gov/Engineering/Calculations/index_Calcs.htm)  
!>)

All are Prepared and Reviewed in  
Accordance with ENG-033



NSTX Upgrade

FDR Calculation Executive Summaries

May 2011

Prepared By:  
*the NSTX Upgrade Team*



**NSTXU CALC 10-01-02**  
Global Model (Titus)

**NSTXU CALC 12-07-00**  
Umbrella (Titus/Zhang)

**NSTXU CALC 13-03-01**  
DCPS Influence  
Coer(Hatcher/Titus)

**NSTXU CALC 12-02-00**  
Dome Rib (Titus)

**NSTXU CALC 13-03-01**  
DCPS Moment  
Coer(Titus/Woolley)

**NSTXU CALC 133-01-01**  
PF 1 abc(Myatt)

**NSTXU CALC 12-05-00**  
PF2 and 3 Coil  
&Sup(Titus/Zatz)

**NSTXU CALC 131-01-01**  
PF Coils (Woolley)

**NSTXU CALC 133-04-00**  
OH Preload  
Bellevilles(Rogoni/Zatz)

**NSTXU CALC 131-01-01**  
PF Coils (Woolley)

**OH/PF Calculations**

**NSTXU CALC 12-05-00**  
PF4 and 5 Coil  
&Sup(Titus/Zatz)

**NSTXU CALC 133-05-00**  
CS Casing Halo(Brooks/Titus)

**NSTXU CALC 132-04-00**  
TF Outer Leg Support(Zhang)

**NSTXU CALC 133-06-00**  
OH  
Cooling(Zolfaghari/Mardenfeld)


**NSTXU CALC 12-06-00**  
Alum Block(Titus/Smith)

**NSTXU CALC 133-06-00**  
OH Stress(Zolfaghari/HM Fan?  
Danigren?)

**NSTXU CALC 133-07-00**  
OH Coax (Mardenfeld)

**NSTXU CALC 132-11-00**  
CS Casing  
Stresses(Titus/Unassigned)



**NSTXU CALC 55-01-00**  
BusBar Khodak



# Longer Pulse, More Neutral Beam Power, More Plasma Current, Increases Heat Load on Vessel Components



WBS 1.1.1 Plasma Facing Components,  
Global Thermal Analysis of Center Stack –  
Heat Balance NSTX-CALC-11-01-00

Prepared By: Art Brooks, Reviewed by:  
Han Zhang, Cognizant Engineer: Jim  
Chrzanowski








# Longer Pulse, More Neutral Beam Power, More Plasma Current, Increases Heat Loads on Tiles, Increased Disruption and Halo Specs Increase Mechanical Loads on Tiles



*WBS 1.1.1 Plasma Facing Components, Stress Analysis of Tiles NSTX-CALC-11-03-00 Prepared By: Art Brooks, Reviewed by: TBD, Cognizant Engineer: Kelsey Tresemer*




*WBS 1.1.1 Basic Tile Analysis Qualification December 2010 NSTX-CALC-11-02-00 Prepared By: Joe Boales, Reviewed By: Art Brooks Cognizant Engineer: Kelsey Tresemer*



# Sources of Lorentz Loading – The Design Point Spreadsheet

- Loads

- Equilibria – Jon Mennard
- 10% “Headroom” – Charlie Neumeyer
- Power Supply Maxima and Minima – Charlie Neumeyer



**Qualification is based on Max and Min loads and load combinations for the 96 Equilibria from the Design Point :**

**With and Without Plasma**

**Circular or Shaped Plasma**


**With Inductively Driven Currents from the Disruption**

*WBS 1.5.2 Force Influence Matrix  
Coefficients NSTXU-CALC-13-03-01  
Prepared by Ron Hatcher, Review by: Peter Titus, Cognizant Engineer: Ron Hatcher*

**Max and Min Loads for the Scenarios are Tabulated**




**Worst Case Power Supply Loads are Tabulated**

**Very few areas are being qualified using maximum power supply loads from the design point. They were “Onerous”**



# What do We Do If We Compute the Loads In the Analysis Models?



One Way is to Compute the Influence Coefficients as you Would For the DCPS and Calculate the Stress in a Spreadsheet. The Plasma can be Turned On and Off in the Spreadsheet – Remember to add 10% Headroom



**WBS 1.1.3 TF Inner Leg Torsional Shear, Including Input to the DCPS**  
**NSTXU-CALC-132-07-00,**  
**Prepared By: Peter Titus, Reviewed by**  
**Bob Woolley**  
**Cognizant Engineer: Jim Chrzanowski**


# Screening Results for All 96 Scenarios, With 10% Headroom, Shaped and Circular Plasmas

*EQ1 (&16) produces the highest stress in the Center Casing  
(particularly from a Post Circular plasma disruption)*





# All New Center Stack Requires New Analysis and Qualification

## Cooling and Stress are Critical Sizing Issues



**OH Stress Calculation NSTX-CALC-133-08-00, OH Stress Analyses**

*Prepared by: Ali Zolfaghari,  
Reviewed by: H.M. Fan  
Cognizant Engineering: Jim Chrzanowski*




**Stress Intensity in the OH Coil Due to Self Currents and Interaction with Current in Adjacent PF1A Poloidal Field Coil**

**This Stress is not Accessible by Influence Calcs**

# OH Cooling Requires Metered Flow to Avoid Excessive Cooldown Stress



OH Stress Calculation NSTXU-CALC-133-08-00, OH Stress Analyses

Prepared by: Ali Zolfaghari, Reviewed by: H.M. Fan  
Cognizant Engineering: Jim Chrzanowski



Coolant "Wave" Arrives at the End of the Coil in Different Times Depending on Path Length in the Layer

OH Coolant Hole Optimization, NSTXU-CALC-133-06-00  
Prepared by: Ali Zolfaghari, Cognizant Engineering: Jim Chrzanowski







# Sizing of the Machine is Driven by the OH Cyclic Stress Limit

## OH Coil Hoop and Tresca Stress

New Conductor w/ 0.225" Dia. Hole, 24kA OH Current, Self Hoop stress is acceptable.


New Conductor w/ 0.225" Dia. Hole, 24kA OH Current, Mid-plane Tresca stress.



The OH Conductor Must have Manufacturing In-Process NDE to Meet Allowables  
 Gary Voss has Provided Luvata Eddy Current Information – We are Evaluating  
 whether Volumetric Inspection is Needed.

**(No Braze Joint has been Qualified)**

WBS 1.1.3 OH Conductor Fatigue Analysis Calculation  
 Number NSTXU-CALC-133-09, Prepared By: Peter Titus,  
 Reviewed by Irv Zatz Cognizant Engineer: Jim Chrzanowski






The OH Coax is at Bottom of the OH Coil. It is not Effected by the Vertical Expansion of the OH , But it is Effected by the Radial Expansion of the OH

**WBS 1.1.3 OH Coax and Lead Conductor Analysis**  
**Calculation Number NSTXU-CALC-133-07**  
**Prepared By: Michael Mardenfeld , Reviewed By:**  
**Unassigned, Cognizant Engineer: Jim Chrzanowski**



D: Transient Thermal  
 Temperature  
 Type: Temperature  
 Unit: °C  
 Time: 9618.1  
 3/16/2011 1:48 PM

59.88 Max  
 58.936  
 57.992  
 57.048  
 56.104  
 55.161  
 54.217  
 53.273  
 52.329  
 51.385  
 50.441  
 49.497  
 48.554  
 47.61  
 46.666 Min






APR 29 2011 ANSYS  
 16:59:27  
 NODAL SOLUTION  
 STEP=1  
 SUB =1  
 TIME=1  
 BFETEMP (AVG)  
 RSYS=0  
 PowerGraphics  
 EFACET=1  
 AVRES=Mat  
 DMX =.005317  
 SMN =30  
 SMX =100

ZV =1  
 \*DIST=.226133  
 \*XF =.17986  
 \*YF =-2.04767  
 Z-BUFFER  
 30  
 37.7778  
 45.5556  
 53.3333  
 61.1111  
 68.8889  
 76.6667  
 84.4444  
 92.2222  
 100



The OH Must be Held in Contact with the Lower G-10 Support Skirt to Disallow the Possibility of separation and loading the terminations and Coolant Connections. This must be done for all Launching Loads, and Thermal Conditions

**OH Coil Pre Load System**



Spring dimensions:  
26 disk springs/stack  
Di = 30.5 mm  
De =60.0 mm  
t = 3.5 mm  
Lo =5.0 mm  
E = 206,000. Mpa  
mu = 0.3

Required gap = 23.87 mm (maximum permitted compression on the stack. Protects overloading of permitted spring stresses.)

Supporting calculations:

“TFhot OHcold26\_14.ppt”  
“TFcoldOHhot26\_14.ppt”  
“TFhotOHhot26\_14.ppt”  
“Spring Calculations in mm.x”

Required 14 stack to maintain a minimum of 20,000. lbs. total load on the OH coil

TF Temp.	OH Temp.	TF Current	OH Current	Launch Force	Peak OH Stress	Peak TF Stress	Peak Displacement	OH Lifted?	Case #	Notes
COLD	COLD	OFF	OFF	OFF	7-14 MPA	7-14 MPA	0.6 mm TF	NO	00000	Bellville staff force only
HOT	COLD	ON	OFF	OFF	102-115 MPA	38-51 MPA	8.8 mm TF	NO	10100	TF grows pushing OH laterally
COLD	HOT	OFF	OFF	OFF	10-19 MPA	19-29 MPA	4.6 mm OH	NO	01000	
COLD	HOT	OFF	ON	OFF	125-140 MPA	16-31 MPA	1.6 mm OH	NO	01010	TF was off and OH current was turned on with hoop stress only
COLD	HOT	OFF	ON	ON	123-138 MPA	16-31 MPA	1.9 mm OH	NO	01011	TF was off and OH current was turned on with hoop stress and launch force.
HOT	COLD	ON	ON	ON	117-132 MPA	15-29 MPA	8.2 mm TF	NO	10111	Just in case, OH getting current before heating up
HOT	HOT	ON	ON	ON	110-134 MPA	15-19 MPA	8.3 mm	NO	11111	


WBS 1.1.3 OH Preload System & Belleville Spring Design NSTX-CALC-133-04-00, Prepared By: Peter Rogoff, Tested by T. Kozub, Cognizant Engineer: Jim Chrzanowski



Note: Spring should be made from SS 301 material. Depending on Stainless Steel conditions modulus of elasticity may be slightly different. In this case, minimum load on the OH coil may decrease by a small percentage ( say 3 to 5%) while everything else will stay the same.

# New Inner PF's Require Qualification


**PF1a**



ANSYS 13.0  
 APR 22 2011  
 09:53:14  
 pfcoils2ds310\_6\_11  
 NODAL SOLUTION  
 STEP=2  
 SUB =2 **EQ51**  
 TIME=11  
 SZ (AVG)  
 RSYS=0  
 DMX =.523E-03  
 SMN =.397E+07  
 SMNB= .248E+07  
 SMX =.169E+08  
 SMXB= .181E+08

Blue	.397E+07
Light Blue	.541E+07
Cyan	.684E+07
Green	.828E+07
Light Green	.971E+07
Yellow	.111E+08
Orange	.126E+08
Red-Orange	.140E+08
Red	.155E+08
Dark Red	.169E+08


**PF1b**



ANSYS 13.0  
 APR 22 2011  
 11:03:02  
 pfcoils2ds310\_9  
 NODAL SOLUTION  
 STEP=1  
 SUB =7 **EQ18**  
 TIME=9  
 SZ (AVG)  
 RSYS=0  
 DMX =.208E-03  
 SMN =.194E+08  
 SMNB= .187E+08  
 SMX =.292E+08  
 SMXB= .298E+08

Blue	.194E+08
Light Blue	.205E+08
Cyan	.216E+08
Green	.227E+08
Light Green	.238E+08
Yellow	.249E+08
Orange	.259E+08
Red-Orange	.270E+08
Red	.281E+08
Dark Red	.292E+08


**PF1c**



ANSYS 13.0  
 APR 22 2011  
 12:31:45  
 pfcoils2ds310  
 NODAL SOLUTION  
 STEP=1  
 SUB =1 **EQ33**  
 TIME=1  
 SZ (AVG)  
 RSYS=0  
 DMX =.597E-03  
 SMN =-.236E+08  
 SMNB= -.273E+08  
 SMX =.140E+08  
 SMXB= .192E+08

Blue	-.236E+08
Light Blue	-.194E+08
Cyan	-.153E+08
Green	-.111E+08
Light Green	-.689E+07
Yellow	-.271E+07
Orange	.147E+07
Red-Orange	.565E+07
Red	.983E+07
Dark Red	.140E+08


**EQ54**



ANSYS 13.0  
 APR 22 2011  
 10:04:45  
 pfcoils2ds310\_12  
 NODAL SOLUTION  
 STEP=1  
 SUB =7  
 TIME=12  
 SINT (AVG)  
 DMX =.630E-03  
 SMN =.454E+07  
 SMNB= .450E+07  
 SMX =.297E+08  
 SMXB= .341E+08

Blue	.454E+07
Light Blue	.734E+07
Cyan	.101E+08
Green	.129E+08
Light Green	.157E+08
Yellow	.185E+08
Orange	.213E+08
Red-Orange	.241E+08
Red	.269E+08
Dark Red	.297E+08


**EQ18**




ANSYS 13.0  
 APR 22 2011  
 11:05:14  
 pfcoils2ds310\_9  
 NODAL SOLUTION  
 STEP=1  
 SUB =7  
 TIME=9  
 SINT (AVG)  
 DMX =.208E-03  
 SMN =.196E+08  
 SMNB= .195E+08  
 SMX =.340E+08  
 SMXB= .361E+08

Blue	.196E+08
Light Blue	.212E+08
Cyan	.228E+08
Green	.244E+08
Light Green	.260E+08
Yellow	.276E+08
Orange	.292E+08
Red-Orange	.308E+08
Red	.324E+08
Dark Red	.340E+08

**WBS 1.1.3 Structural Analysis of the PF1 Coils Leads and Supports, Rev1 NSTX-CALC-133-01-01**  
 Prepared By: Leonard Myatt, Reviewed by: TBD, Cognizant Engineer: Jim Chrzanowski



*The 3D PF1a/b model reproduces the max axisymmetric mandrel stress of away 140 MPa from the most significant 3D structural features*




*The winding shell flexure at the lead opening produces some significant local stresses:*

- Mem: 156 MPa (<300 MPa 🐣)*
- M+B: 340 MPa (<450 MPa 🐣)*
- Peak: 515 MPa (fatigue TBD)*




# Shear Stresses are < 2 Mpa – Only CTD 101 K without Primer is Required





**PF1a**




**PF1b**



**PF1c**




# Past Difficulties with the TF Joint Demand a New Robust Joint Design




**TF Flex Joint and TF Bundle Stub NSTXU-CALC-132-06-00**  
**Prepared By: Tom Willard, Reviewed by: Ali Zolfaghari**  
**Cognizant Engineer: Jim Chrzanowski**

**Contact Pressures are Maintained with a Large Margin - Based on Lessons Learned form Original NSTX Flag**



**Contact Pressure**



**Current Density Distribution - Temperature Agrees with Han's Coupled EM-Thermal Analysis**

**TF Flex Joint and TF Bundle Stub NSTXU-CALC-132-06-00**

**Prepared By: Tom Willard, Reviewed by: Ali Zolfaghari**


**Cognizant Engineer: Jim Chrzanowski**

**TF Coupled Thermal Electromagnetic Diffusion Analysis,**

**NSTXU-CALC-132-05-01,**


**Prepared By: Han Zhang, Reviewed by Yuhu Zhai,**

**Cognizant Engineer: Jim Chrzanowski**




**Temperature Distribution at EOP**

# Up to 40% of the Plasma Current is Inductively Driven in The Centerstack During a Disruption






WBS 1.1.1 Disruption Analysis of Passive Plates, Vacuum Vessel & Components  
 NSTXU-CALC-12-01-01 Rev 1 April, 2011  
 Prepared By: Peter Titus, Contributing Authors: A. Brooks, Srinivas Avasarala,  
 J. Boales Reviewed By: Yu Hu Zhai, Cognizant Engineer: Peter Titus






**The Tall Narrow Centerstack Could Experience Excessive Lateral Loads If Peaking Factors are Sustained.**




**WBS 1.1.3 Magnet Systems, Halo Current  
Analysis of Center Stack  
NSTXU-CALC-133-05-00  
Prepared By: Art Brooks, Reviewed by:  
Peter Titus,  
Cognizant Engineer: Jim Chrzanowski**




**Stress Due  
Halo Current  
Strike**




## Stress Due Thermal Distribution



**WBS 1.1.1 Plasma Facing Components, Global Thermal Analysis of Center Stack – Heat Balance NSTX-CALC-11-01-00**  
**Prepared By: Art Brooks, Reviewed by: Han Zhang, Cognizant Engineer: Jim Chrzanowski**



## Stress Due to PF Loads




**WBS 1.1.3 Structural Analysis of the PF1 Coils Leads and Supports, Rev1 NSTX-CALC-133-01-01**  
**Prepared By: Leonard Myatt, Reviewed by: TBD, Cognizant Engineer: Jim Chrzanowski**


**NSTX Upgrade Centerstack Casing Stress Summary NSTXU-CALC-133-03-00**  
**Rev 0 May 2011 Prepared By: Peter Titus, PPPL Engineering Analysis Branch, Contributing Authors: A. Brooks, L. Myatt**  
**Reviewed By: Unassigned**  
**Jim Chrzanowski, NSTX Cognizant Engineer**

**Thermal +Lorentz +Inductive + Halo**  
**261 + 42 + 1 + 60 = 364**

**Bellows Allow Vertical Expansion of the Centerstack Casing – This is Axial Motion, but Lateral and Torsional Loads Exist**



**Note:** All stresses reported are for cqquad4 surface "Z2". This is the bellows inside surface.



**WBS 1.1.3 Center Stack Casing Bellows, Calculation Number NSTXU-CALC-133-10-00**  
**Prepared By: Peter Rogoff, Reviewed by Irv Zatz**  
**Cognizant Engineer: Jim Chrzanowski**

- Halo Current Loads (upper bellows only). Reference calculation #NSTX CALC 133-04-00.
- The upper bellows must allow thermal motion due to the bake-out and the normal operation where heat from the plasma is transferred to the CS casing through the insulating tiles. Reference calculation # NSTX CALC 11-01-00.
- The upper bellows must support the seismic loads, Reference calculation #NSTX CALC 10-01-02.
- The upper and lower bellows transmit some portion of the torsional moment from the upper vessel structure to the center stack casing. This moment comes through the umbrella structure, Reference calculation # NSTX CALC 10-01-02.

• Pressure due to vacuum conditions.




These calculations were performed using:

- EJMA (Expansion Joint Manufacturers Association) Basic equations presented in section 4.13 of the manual.
- NASTRAN Version MSC FEA x64 2010.1.2 finite element code.

# The Upper End of the Centerstack Casing is Only Coupled to the Rest of the Machine Through the Bellows

Magnetic Stability of PF's and OH


The Centerstack Stability with Respect to the Rest of the Poloidal Coil System relies on the stiffness of the Upper and Lower Lid – and some centering system of the OH with Respect to the TF (Bumpers in the Gap? Lateral Stiffness of the Belleville Spring Stacks?)



Stability of PF1a,b with Respect to the OH

Other Stabilities Need to Be Addressed

PF1a Support Lateral Stiffness (Dominated by the Bellows)




Magnetic Stability of PF1a With Respect to the OH  
A Zolfaghari MAXWELL Results

PF1a is supported off the centerstack casing which is stabilized laterally by the bellows/ceramic break assembly. The stiffness of the supports must be sufficient to overcome the magnetic stiffness. To quantify the magnetic stiffness the Lorentz force between the OH and PF1a coils was calculated for different lateral offsets.

PF1a and Oh coils dimensions and arrangement were used from the latest design point.


Coil	Current (kA)	Turns
OH	24	884
PF1a	18.3	64

The PF1a is moved 2mm and 5mm in the positive Y direction.







Magnetic Stiffness=  
3189/.005 N/m =  
.637MN/m

Orientation of currents	PF1a Offset (mm) in +Y direction	Force on PF1a (N) in +Y Direction
Parallel	2	1191
Opposite	2	-1255
Parallel	5	3167
Opposite	5	-3189
Parallel	0	-141
Opposite	0	125





# Single Width "Blade" Or Bitter Magnet Design Introduces Possibility of Transient Coupled Electromagnetic Thermal Diffusion





B. Toroidal field plot

TF Coupled Thermal Electromagnetic Diffusion Analysis,  
NSTXU-CALC-132-05-01,  
Prepared By: Han Zhang, Reviewed by Yuhu Zhai,  
Cognizant Engineer: Jim Chrzanowski







# Single Width "Blade" Or Bitter Magnet Design Introduces Possibility of Transient Coupled Electromagnetic Thermal Diffusion




**TF Coupled Thermal Electromagnetic  
Diffusion Analysis,  
NSTX-CALC-132-05-01,  
Prepared By: Han Zhang, Reviewed by Yuhu  
Zhai,  
Cognizant Engineer: Jim Chrzanowski**

# TF Coils are at the Thermal Limit for Epoxies



**TF Coupled Thermal  
 Electromagnetic  
 Diffusion Analysis,  
 NSTXU-CALC-132-05-  
 01,  
 Prepared By: Han  
 Zhang, Reviewed by  
 Yuhu Zhai,  
 Cognizant Engineer:  
 Jim Chrzanowski**


# ***TF Flex Must be Conduction Cooled from Its Ends – Higher Resistivity High Strength Friction Stir Welded Flag Must Perform Adequately Thermally***



***TF Coupled Thermal Electromagnetic Diffusion Analysis, (Part 2)***  
***NSTXU-CALC-132-05-01,***  
***Prepared By: Han Zhang, Reviewed by Yuhu Zhai,***  
***Cognizant Engineer: Jim Chrzanowski***

***TF Cool-down using FCOOL CALC-132-10-00***  
***Prepared by: Ali Zolfaghari, Reviewed by: Mike Kalish***  
***Cognizant Engineer: Jim Chrzanowski***

# Higher Resistivity High Strength Friction Stir Welded Flag Must Perform Adequately



**TF Coupled Thermal Electromagnetic Diffusion Analysis, (Part 2)**  
**NSTXU-CALC-132-05-01,**  
**Prepared By: Han Zhang, Reviewed by Yuhu Zhai,**  
**Cognizant Engineer: Jim Chrzanowski**

# Existing NSTX has been Cyclically Loaded. Many Existing Weldments are not "Fatigue Friendly"

*Qualify Analytically  
Where Possible*


*Add  
Reinforcements/Radii*

*Inspect*

*Avoid Fatigue Sensitive  
Welds*



*Small Fillets?  
Intermittent Welds?  
Partial Penetration*

*Consider Peening*




PF2 and PF3 Upper Loads Plus TF OOP Loads

```
ANSYS 12.1
MAY 16 2011
13:57:46
NODAL SOLUTION
STEP=3
SUB =1
TIME=3
SEQV (AVG)
PowerGraphics
EFACET=1
AVRES=Mat
DMX =.001487
SMN =97.755
SMX =.114E+10
XV =-.57735
XV =-.57735
XV =-.57735
XV =-.57735
*DIST=-.38912
*XF =1.165
*YF =1.766
*ZF =-.05078
Z-BUFFER
Z-BUFFER
0
.175E+08
.350E+08
.525E+08
.700E+08
.105E+09
.122E+09
.140E+09
.158E+09
```






# The Tokamak is Multiply Redundant, Global Model Model Simulations are Required



*Analysis of TF Outer Leg, NSTXU-CALC-132-04-00, Prepared By: Han Zhang, Reviewed by Peter Titus  
Cognizant Engineer: Mark Smith*




*WP 1.1.1 Seismic Analysis NSTXU-CALC-10-02-00, Prepared by Peter Titus, Reviewed by F. Dahlgren, Cognizant Engineer: Peter Titus*





**Global Model Is Used For:**

- Address Statically Indeterminate Structures*
- Selecting Worst Cases*
- Scoping Studies*
- Providing Boundary Conditions for Other Models*
- Cross-Checking other Models*
- Seismic Analysis*


*WP 1.1.0 NSTX Upgrade Global Model – Model Description, Mesh Generation, and Results NSTXU-CALC-10-01-02 Prepared by Peter Titus, Reviewed by Unassigned, Cognizant Engineer: Peter Titus*



# Global Model Model is Used for the Seismic Analysis




MCE and 5% Damped MCE Ground Motion




WP 1.1.1 Seismic Analysis NSTXU-CALC-10-02-00,  
Prepared by Peter Titus, Reviewed by F. Dahlgren,  
Cognizant Engineer: Peter Titus



# TF In-Plane Load is Four Times Larger



**WBS 1.1.2 Upgrade TF to Umbrella Structure Aluminum Block Connection**  
**NSTXU-CALC-12-06-00,**  
**Prepared By: Peter Titus,**  
**Reviewed By: Mark Smith,**  
**NSTX Cognizant Engineer**  
**Mark Smith**








**Analysis of TF Outer Leg,**  
**NSTXU-CALC-132-04-00,**  
**Prepared By: Han Zhang,**  
**Reviewed by Peter Titus**  
**Cognizant Engineer: Mark**  
**Smith**

**WBS 1.1.2 Ring Bolted Joint,**  
**NSTXU-CALC-132-11-00**  
**Prepared By: Peter Rogoff,**  
**Reviewed By Irv Zatz,**  
**Cognizant Engineer: Mark Smith**


# Out-of-Plane Torque is Much Larger Inner Leg Torsional Shear is Limiting

## TF Inner Leg Torsional Shear


Bob Woolley's  
Moment Sum



**WBS 1.1.3 TF Inner Leg Torsional Shear, Including Input to the DCPS NSTXU-CALC-132-07-00, Prepared By: Peter Titus, Reviewed by Bob Woolley Cognizant Engineer: Jim Chrzanowski**




**The Max torsional shear is 24 MPa with an allowable of 21.7 MPa**






# Calculation of Inner Leg Torsional Shear Using the Global Model Derived Influence Coefficients


Due to Unit Current in OH si01




Due to Unit Current in Ip




Due to Unit Current in PF1aU




Due to Unit Current in PF1bU, si03



Due to Unit Current in PF1cU, si04






Due to Unit Current in PF2U, si05



Note: Scale  
has been  
adjusted,  
and TFON  
Subtracted


**WBS 1.1.3 TF Inner Leg  
Torsional Shear,  
Including Input to the  
DCPS  
NSTXU-CALC-132-07-00,  
Prepared By: Peter  
Titus, Reviewed by Bob  
Woolley  
Cognizant Engineer: Jim  
Chrzanowski**

# Calculation of Inner Leg Torsional Shear Using the Global Model Derived Influence Coefficients







WBS 1.1.3 TF Inner Leg Torsional Shear, Including Input to the DCPS  
 NSTXU-CALC-132-07-00,  
 Prepared By: Peter Titus, Reviewed by Bob Woolley  
 Cognizant Engineer: Jim Chrzanowski

# Bob Wooley's Calculation of Inner Leg Torsional Shear Using Mark Smith's Global Model Stiffnesses



Important Node Numbers In Torsion Membrane Model




**Peak torsional shear stress in the TF centerstack calculated by these methods is 25.18 MPa. Bob's Shears are Up-Down Symmetric**


**With Similar Stiffnesses to Bob Woolley/Mark Smith, Titus's Analysis Produces Up-Down Symmetry**

**WP 1.1.0 NSTX Upgrade Global Model – Model Description, Mesh Generation, and Results NSTXU-CALC-10-01-02**  
 Prepared by Peter Titus, Reviewed by Unassigned, Cognizant Engineer: Peter Titus


**Lower Structure Stiffness Effect on TF Inner Leg Torsional Shear**




**WBS 1.1.2 Lid/Spoke Assembly, Upper & Lower**  
 NSTX-CALC-12-08-00 Rev 0 May 2011  
 Prepared by: Peter Titus, Reviewed By: Unassigned, Cognizant Engineer: Mark Smith



Rotationally Compliant Pedestal/Stiff Lower Lid



Rotationally Stiff Pedestal/Stiff Lower Lid




Rotationally Stiff Pedestal/Compliant Lower Lid






COMPOSITE TECHNOLOGY DEVELOPMENT, INC.  
ENGINEERED MATERIAL SOLUTIONS



CTD-425 Specimen #15- Fatigue at 60% of Ultimate Stress (31 MPa, 21867 cycles)



CTD-425 Specimen #14- Fatigue at 60% of Ultimate Stress (31 MPa, 26851 cycles)

**Final Test Report**  
**PPPL Purchase Order PE010637-W**

**Fabrication and Short Beam Shear Testing of**  
**Epoxy and Cyanate Ester/Glass Fiber-Copper Laminates**

**April 8, 2011**


Prepared for:  
Princeton Plasma Physics Laboratory  
Forrestal Campus  
US Route 1 North @ Sayre Drive  
Receiving Area 3  
Princeton, NJ 08543

Prepared by:  
Composite Technology Development, Inc.  
2600 Campus Drive, Suite D  
Lafayette, CO 80026

2600 CAMPUS DR., SUITE D • LAFAYETTE, CO 80026 • 303-664-0394 • WWW.CTD-MATERIALS.COM



# CTD Fatigue Tests



CTD 425 W/Cu 3pt Bend Fatigue @ 373 K





Figure 2: CTD-425 S-N chart



CTD 425 W/Cu 3pt Bend





Figure 3: CTD-425 80°C S-N Chart



***With Two Independent Methods, Both Results for the Maximum TF Inner Leg Torsional Shear are Similar***

***Bob Woolley Gets 25.18 Mpa***

***P. Titus Gets:***

***Based on the DCPS influence coefficient TF inner leg upper corner torsional shear stresses, for all scenarios, are all below 20 MPa with and without plasma. Rigorously these should have the 10% headroom applied (the coefficients do not include this) - So the torsional shear stress to compare with the allowable is 22 MPa.***

***2. We have CTD -425 Qualification for 20 Mpa at 100C for ~ 300,000 cycles***

# Out-of-Plane Torque Equations in the Design Point Spreadsheet

**WBS 1.1.0 NSTXU 132-03-00, Torques On TF Conductors & Resulting Torsion & Shear Stress in NSTX CSU, 04 May2010 Design Point, Prepared by R. Woolley Reviewed by Peter Titus, Cognizant Engineer: Peter Titus**

**Global Torque Sums Agree with FEA Calculations by Willard and Titus**

$$\left[ \frac{\text{Net TF System Outer Leg Torque}}{1 \text{ N - m}} \right] = 3519.9 \left[ \frac{I_{PF1AU} - I_{PF1AL}}{1 \text{ kA}} \right]$$

$$+ 3692.0 \left[ \frac{I_{PF1BU} - I_{PF1BL}}{1 \text{ kA}} \right] + 4293.8 \left[ \frac{I_{PF1CU} - I_{PF1CL}}{1 \text{ kA}} \right]$$


$$+ 13191 \left[ \frac{I_{PF2U} - I_{PF2L}}{1 \text{ kA}} \right] + 16497 \left[ \frac{I_{PF3U} - I_{PF3L}}{1 \text{ kA}} \right]$$

$$\left[ \frac{\text{Net Upper Half TF System Torque}}{1 \text{ N - m}} \right] = 13563.1 \left[ \frac{I_{OH}}{1 \text{ kA}} \right] + 2260.9 \left[ \frac{I_{PF1AU} + I_{PF1AL}}{1 \text{ kA}} \right]$$


$$+ 1580.6 \left[ \frac{I_{PF1BU} + I_{PF1BL}}{1 \text{ kA}} \right] + 1851.5 \left[ \frac{I_{PF1CU} + I_{PF1CL}}{1 \text{ kA}} \right]$$

$$+ 5197.5 \left[ \frac{I_{PF2U} + I_{PF2L}}{1 \text{ kA}} \right] + 21915.7 \left[ \frac{I_{PF3U} + I_{PF3L}}{1 \text{ kA}} \right]$$

$$+ 56813.9 \left[ \frac{I_{PF4}}{1 \text{ kA}} \right] + 118636.5 \left[ \frac{I_{PFSU}}{1 \text{ kA}} \right] + 713308.9 \left[ \frac{I_{\text{plasma}}}{1 \text{ MA}} \right]$$




# Hoop Tension Develops from Thermal Distribution



NODAL SOLUTION  
STEP=652  
SUB =1  
TIME=10.136  
SY (AVG)  
RSYS=1  
PowerGraphics  
EFACET=1  
AVRES=Mat  
DMX =.008521  
SMN =-.713E+08  
SMX =.478E+08

Legend values:  
-.478E+08  
-.372E+08  
-.266E+08  
-.159E+08  
-.531E+07  
.531E+07  
.159E+08  
.266E+08  
.372E+08  
.478E+08


0.25" tube  
Max: 48MPa (6.9ksi)



**TF Coupled Thermal Electromagnetic Diffusion Analysis, (Part 2)**  
**NSTX-CALC-132-05-01,**  
**Prepared By: Han Zhang, Reviewed by Yuhu Zhai,**  
**Cognizant Engineer: Jim Chrzanowski**




# Hoop Tension Develops from Thermal Distribution. But Not Where Torsional Shear is Greatest.




ANSYS

NODAL SOLUTION  
 STEP=412  
 SUB =1  
 TIME=10.134  
 ET = (AVG)  
 SPTS=1  
 PowerGraphics  
 EFACET=1  
 AVRES=Mat  
 SML = .009121  
 SMN = -.717E+08  
 SMX = -.478E+08  
 SML = -.478E+08  
 SMN = -.572E+08  
 SMX = -.246E+08  
 SML = -.246E+08  
 SMN = -.119E+08  
 SMX = -.331E+07  
 SML = -.159E+08  
 SMN = -.246E+08  
 SMX = -.372E+08  
 SML = -.478E+08


No Plasma  
Data Set # 9913



With Plasma  
Data Set # ip13




JAN 25 2011  
 08:09:32  
 NODAL SOLUTION  
 STEP=29  
 SUB =1  
 TIME=29  
 SYZ (AVG)  
 RSYS=0  
 PowerGraphics  
 EFACET=1  
 AVRES=Mat  
 DMX = .009467  
 SMN = -.988E+08  
 SMX = .747E+08  
 ZV = 1  
 \*DIST=.561881  
 \*XF =.076462  
 \*YF =2.77342  
 \*ZF =-.159871  
 Z-BUFFER  
 -.200E+08  
 -.150E+08  
 -.100E+08  
 -.500E+07  
 0  
 .500E+07  
 .100E+08  
 .150E+08  
 .200E+08  
 .250E+08



**TF Coupled Thermal Electromagnetic Diffusion Analysis, (Part 2)**  
**NSTXU-CALC-132-05-01,**  
 Prepared By: Han Zhang, Reviewed by Yuhu Zhai,  
 Cognizant Engineer: Jim Chrzanowski


**WBS 1.1.3 TF Inner Leg Torsional Shear, Including Input to the DCPS**  
**NSTXU-CALC-132-07-00,**  
 Prepared By: Peter Titus, Reviewed by Bob Woolley  
 Cognizant Engineer: Jim Chrzanowski

*CTD 425 is a Blend which Uses the CTD 450 Cyanate Ester Primer . Adhesion of the insulation is expected to be governed by Cyanate Ester Properties. Zero Shear Tension Capacity at 80C is 60 Mpa.*




*If there is Tensile or Shear Failure, It is desirable to have debonding at the Copper /Insulator Interface.*

*From the CTD 425 Fatigue Qualification:*




CTD-425 Specimen #15- Fatigue at 60% of Ultimate Stress (31 MPa, 21867 cycles)



CTD-425 Specimen #14- Fatigue at 60% of Ultimate Stress (31 MPa, 26851 cycles)


*From Gary Voss Paper on Cyanate Ester*

## Inner leg Torques are Partially Reacted by Connections to the Spoked Lids




Wrap/Bond G-10 Strip

Loads Teeth in Strong Direction



### Analysis of the TF Flag Key

A double-spline design for the G10 Crown will relieve stress on the crown teeth and insulation. Design is being analyzed.



NSTX

Peer Review

April 29, 2010





56

**Determination of Shear Forces between the TF Conductors**  
NSTX-CALC-132-08-00

Prepared by: Ali Zolfaghari, Reviewed by: Tom Willard  
Cognizant Engineering: Jim Chrzanowski

# Pinned Connections are Used on Top and Bottom

## Moment From Spoked Lid Analysis




**See: NSTXU 132-03-00,  
 Torques On TF Conductors  
 & Resulting Torsion &  
 Shear Stress in NSTX CSU,  
 by R. Woolley or,**

**TF Inner Leg Torsional  
 Shear, Including Input to  
 the DCPS  
 NSTXU-CALC-132-07-00,  
 Prepared By: Peter Titus,  
 For Inner Leg Shear**

**Determination of Shear Forces  
 between the TF Conductors  
 NSTX-CALC-132-08-00  
 Prepared by: Ali Zolfaghari,  
 Reviewed by: Tom Willard  
 Cognizant Engineering: Jim  
 Chrzanowski**



# Out-of-Plane Torque is Much Larger. Most is taken by the Vessel, Some by the TF Outboard Legs, A little by the CS Casing and Central Column



# Out-of-Plane Torque Must be Taken by Existing Structural Load Paths – Can the Vessel Take It?


Basic Elements of the OOP Load Carrying “Logic” Remain: i.e.  
Global Twist is Carried Predominantly by the Vacuum Vessel Equatorial Region With Some Help from TF

TF OOP Loads are Still transferred to Umbrella Structure and Knuckle Clevis

We tried other things – “Diamond Truss”, “Top Hat” and Truss to the Cell Walls


**WBS 1.1.2 Vessel Rework for the Neutral Beam and Thomson Scattering Port**  
**NSTXU-CALC-24-01-00**

Prepared By: T. Willard Reviewed by: A. Zolfaghari  
Cognizant Engineers: M. Smith, G. Labik, C. Priniski




Eddy Current Density on Vacuum Vessel w/o Ports: End of Quench

1ms Centered-Plasma Disruption: Current Scenario #79 w/ Headroom Background Field




Static Structural Results, Ports Excluded from EM Solution: von Mises Stress  
1ms Centered-Plasma Disruption: Current Scenario #79 w/ Headroom Background Field


# Outer Leg In-Plane and Out-of-Plane Support Many Concepts Were Tried – Many had Interference Problems




*Diamond Truss*




*Pinned Ring Rigid Truss*



*Rigid Ring to Existing Clevis*



*Soft Springs to Existing Clevis*



**Outer Leg Support Must Control:**

**Copper Stress**

**Bending Related Bond Shear**

**Loads at Attachment Points**

**Displacements**


**Analysis of TF Outer Leg, NSTXU-CALC-132-04-00, Prepared By: Han Zhang, Reviewed by Peter Titus  
Cognizant Engineer: Mark Smith**

**WBS 1.1.2 TF Strut to Vessel Knuckle Clevis Connection  
NSTXU-CALC-132-09-00  
Rev 0 March 2011, Prepared By: Peter Titus, Reviewed by Han Zhang, Mark Smith, NSTX  
Cognizant Engineer**






# Existing Clevis Was Offset From the Surface of the Vessel and Was Held On by 5/16 Screws – It Had Little Load Capacity

TF Truss or Radius Rod Lug




Actual (2009) Weld Size is 3/16

Model Weld is 8.6mm










# Welded Clevis Replacement



Shear load is taken by "lips"


eccentricity produces a moment and tension at the stud pattern

Forces intersect the centroid of the stud pattern - no moment is produced.



Ref [1] Preliminary Result from Wednesday Meeting. This Detail needs to be radiused


**WBS 1.1.2 TF Strut to Vessel Knuckle Clevis Connection**  
**NSTXU-CALC-132-09-00 Rev 0 March 2011, Prepared By: Peter Titus, Reviewed by Han Zhang, Mark Smith, NSTX Cognizant Engineer**



# Clamps Produce Local Stress Concentrations


– Leg Braces Help – Do we Need Them?

Scenario 49



ANSYS NODAL SOLUTION  
STEP=2  
SUB =1  
TIME=2  
SBOV (AVG)  
PowerGraphics  
EFACET=1  
AVRES=Mat  
DMX =.004417  
SMN =363493  
SMX =.866E+08  
363493  
.995E+07  
.195E+08  
.291E+08  
.387E+08  
.483E+08  
.579E+08  
.674E+08  
.770E+08  
.866E+08

12.5 ksi




ANSYS NODAL SOLUTION  
STEP=2  
SUB =1  
TIME=2  
SINT (AVG)  
PowerGraphics  
EFACET=1  
AVRES=Mat  
DMX =.006271  
SMN =359576  
SMX =.175E+09  
359576  
.197E+08  
.391E+08  
.585E+08  
.779E+08  
.973E+08  
.117E+09  
.136E+09  
.155E+09  
.175E+09

25.4 ksi


*This is the result with/without coil reinforcement. Without reinforcement, max stress is 90MPa. With reinforcement, it reduces to 86MPa. Comparing with previous spring design, 175MPa, it seems the tie bar stiffness is the main factor for coil stress..*

Tie bar modulus: 2E11 (with coil reinforcement)



ANSYS NODAL SOLUTION  
STEP=2  
SUB =1  
TIME=2  
SBOV (AVG)  
PowerGraphics  
EFACET=1  
AVRES=Mat  
DMX =.004417  
SMN =363493  
SMX =.866E+08  
363493  
.104E+08  
.204E+08  
.304E+08  
.404E+08  
.504E+08  
.605E+08  
.705E+08  
.805E+08  
.905E+08


Tie bar modulus: 2E11 (no coil reinforcement)



“Leg Brace”

“Clamp”


ANSYS design



clevis  
Reinforcement to the coil  
Clamp modified


**Analysis of TF Outer Leg, NSTXU-CALC-132-04-00, Prepared By: Han Zhang, Reviewed by Peter Titus Cognizant Engineer: Mark Smith**






**“Clamp”**

*WBS 1.1.2 TF Clamp Assembly  
NSTXU-CALC-132-10-00 Rev 0 March  
2011, Prepared By: Peter Rogff  
Reviewed by Unassigned, Mark Smith,  
NSTX Cognizant Engineer*



**“Leg Brace”**





**“Clamp”**


**NASTRAN MPC  
ANSYS CP**

MSC FEA 2010.1.2 64-Bit 17-May-11 12:59:22  
Fringe: Default, A1:Static Subcase, Displacements, Translational, Magnitude, (NON-LAYERED)

# The Ring Supports the Bursting Loads and OOP rotations. The Bolted Joint is Designed for Tension and Moments



Loads with SPCDs and Moments  
Total Loads



Calculations based on standard equations, See above


See next slide

Problem: 1.0 in. dia. Bolt,  $A_s = .663 \text{ in}^2$ , Yield = 100.ksi, Based on 2/3 yield = 66.7 ksi.  
 $F_p = 66.7 \text{ ksi} \times .663 \text{ in}^2 = 44.22 \text{ Kips per bolt}$ , If  $\mu = .3$ ,  $F_s = 44.22 \text{ Kips} \times .3 = 13,266 \text{ lbs/bolt}$   
 Typical "nut factor" see the torque equation  
 For two bolts  $F_s = 26532. \text{ lbs}$  And required torque =  $44,220 \text{ lbs.} \times .2 \times 1.0 \text{ in.} = 8,844 \text{ lb-in}$



**WBS 1.1.2 Ring Bolted Joint, NSTX-CALC-132-11-00**  
 Prepared By: Peter Rogoff,  
 Reviewed By Irv Zatz,  
 Cognizant Engineer: Mark Smith



# Out-of-Plane Loads Are Transferred from the TF to the Vessel Via the Umbrella Structure as Well. Original Legs Were Too Weak






*WBS 1.1.2 NSTX Upgrade Umbrella Arch and Foot Reinforcements, Local Dome Details, NSTXU-CALC-12-07-00 May 2011 Prepared by: Peter Titus, Han Zhang, Reviewed By: Irv Zatz, Cognizant Engineer: Mark Smith*





# OOP and Vertical Load from Umbrella Legs, PF1c 2, and 3 Loads are Applied to the Ribs. Solid Models Needed Updating

Bruce Paul Built the Solid Model of the Dome Rib Based on Non-Conformance Report






# Dished Head Supports PF1c,2, and 3 Loads



## Sliding Block Allows Bake-Out Motion


**WBS 1.1.2 NSTX Upgrade Umbrella Arch and Foot Reinforcements, Local Dome Details, NSTXU-CALC-12-07-00 May 2011**  
Prepared by: Peter Titus, Han Zhang, Reviewed By: Irv Zatz, Cognizant Engineer: Mark Smith




The Thicker Umbrella Structure Slightly Reduces the Dome Stress




**Out-of-Plane Torque Are Taken by Existing Structural Load Paths – Torque from Umbrella Structure Goes to Umbrella Legs – And to Upper Spoked Lid**



Spoked Lid/Flex 45 degree FEA Model – With Symmetry Expansion



WBS 1.1.2 Lid/Spoke Assembly, Upper & Lower  
 NSTX-CALC-12-08-00 Rev 0 May 2011  
 Prepared by: Peter Titus, Reviewed By: Unassigned,  
 Cognizant Engineer: Mark Smith





**Upper Spoked Lid Must Flex Upward to Allow Thermal Growth of the Centerstack**




# Lower Out-of-Plane Torque Load Path Was Changed to Ensure Adequate Access from Below

**WBS 1.1.2 Analysis of the NSTX Upgrade Centerstack Support Pedestal**  
**NSTXU-CALC-12-09-00 May 2011 Prepared**  
**By: Peter Titus**  
**Reviewed By: Ali Zolfaghari, Cognizant**  
**Engineer: Mark Smith**

Lower Structure Stiffness Effect on TF Inner Leg Torsional Shear




Rotationally Compliant Pedestal/Stiff Lower Lid



Rotationally Stiff Pedestal/Stiff Lower Lid




Rotationally Stiff Pedestal/Compliant Lower Lid



**WBS 1.1.2 Lid/Spoke Assembly, Upper & Lower**  
**NSTX-CALC-12-08-00 Rev 0 May 2011**  
**Prepared by: Peter Titus, Reviewed**  
**By: Unassigned,**  
**Cognizant Engineer: Mark Smith**



# Stiff Pedestal and Soft Lower Spoked Lid Could Introduce Loads on the Bellows



**WBS 1.1.2 Lid/Spoke Assembly, Upper & Lower**  
**NSTX-CALC-12-08-00 Rev 0 May 2011**  
**Prepared by: Peter Titus, Reviewed By: Unassigned,**  
**Cognizant Engineer: Mark Smith**

**Soft "Bent Spoke" Lower Lid was Considered.**



**It Potentially Caused Loading of the Bellows – From Halo Loads as Well as From OOP Torques**



**Stiffer Lower Spoked Lid Connects Umbrella and TF Central Column and Pedestal – Protecting the Bellows**



# PF Vertical or Axial Loads are Larger to Support 2 MA Operation



## PF2,3 Analysis

WBS 1.1.2 PF2 and PF3  
Coils and Support  
Analysis


NSTXU-CALC-12-04-00

Rev0, March 2011


Prepared By: Peter Titus

Reviewed By: Irv Zatz,  
Cognizant Engineer: Mark  
Smith

Current (2010) locations of the PF2 supports, and the proposed location of the seventh support




Model with 6 Fold  
Cyclic Symmetry




# PF Vertical or Axial Loads are Larger to Support 2 MA Operation


## PF4,5 Analysis



**New Stiffer Column**



PF4 and 5 With 12 Support Points  
Six Columns, 6 Existing PF Supports




Terminals are Near Fixed Point

Mylar Wrapped Fusifab Insulation Required 12 Supports

Attractive Loads Between Pancakes Frictionally Augment the Bending Capacity


PF 4 and 5 Max Principal Stresses



**WBS 1.1.2 Analysis of Existing & Upgrade PF4/5 Coils & Supports – With Alternating Columns, NSTX-CALC-12-05-00,**  
Prepared By: Peter Titus, Reviewed by Irv Zatz,  
Cognizant Engineer: Mark Smith



# 5 Second Pulse Adds More Joule Heat in the Coils




*Significant Increases in Temperature Occur in PF 1 a,b And PF4 and 5*




**WBS 1.1.3 Structural Analysis of the PF1 Coils Leads and Supports, Rev1**  
NSTX-CALC-133-01-01  
Prepared By: Leonard Myatt,  
Reviewed by: TBD, Cognizant Engineer: Jim Chrzanowski

**WBS 1.1.2 Analysis of Existing & Upgrade PF4/5 Coils & Supports – With Alternating Columns, NSTXU-CALC-12-05-00,**  
Prepared By: Peter Titus,  
Reviewed by Irv Zatz,  
Cognizant Engineer: Mark Smith

# 5 Second Pulse Adds More Joule Heat in the Coils






*Link Model Used To Model Radial Motion at Added PF4/5 Columns*





# More Plasma Current, Higher TF Field, Higher PF Field, Increase Disruption Electromagnetic Loads in In-Vessel and Ex Vessel Components

*Opera 2D Electromagnetic Analysis NSTXU-CALC-12-03-00  
 Prepared by: Ron Hatcher, Reviewed by: Art Brooks,  
 Cognizant Engineer: Peter Titus*



*Opera Poloidal Fields Re-Constructed in ANSYS From OPERA Vector Potential Output*

# ***Complicated Components Needed to be Qualified. Large Models With Air Were Difficult to Mesh and Analyze Dynamically***






# Complicated Components Needed to be Qualified. Large Models With Air Were Difficult to Mesh and Analyze Dynamically

Dynamic Analysis Results  
Mid Plane Disruption  
Fast Quench of Plasma 1

Same  
/Contour  
Scale as for  
the Mid Plane  
Disruption


Dynamic Analysis Results  
Disruption Near Secondary Passive Plate  
Fast Quench of Plasma 4

2D Opera Results  
Were Imposed as  
Boundary  
Conditions on 3D  
ANSYS  
Electromagnetic  
Models, Then  
Passed to Dynamic  
Structural Analyses



```
ANSYS 12.0.1
SEP 15 2010
07:51:35
NODAL SOLUTION
STEP=9
SUB =10
TIME=100.008
SINT (AVG)
PowerGraphics
EPACRT=1
AVRES=Mat
DMX =.001369
SMX =.103E+10


XV =-.59566
YV =.57715
ZV =.55864
*DIST=.93091
*XF =1.239
*YF =-1.155
*ZF =-.187E-03
A-ZS=-1.06
Z-BUFFER
0
.100E+08
.200E+08
.300E+08
.400E+08
.600E+08
.700E+08
.800E+08
.900E+08
```



```
ANSYS
SEP 15 2010
08:39:50
NODAL SOLUTION
STEP=9
SUB =10
TIME=100.008
SINT (AVG)
PowerGraphics
EPACRT=1
AVRES=Mat
DMX =.00361
SMX =.642E+09

XV =-1
YV =1
ZV =1
*DIST=1.015
*XF =-1.25
*YF =-1.15
*ZF =-.444E-04
Z-BUFFER
0
.100E+08
.200E+08
.300E+08
.400E+08
.500E+08
.600E+08
.700E+08
.800E+08
.900E+08
```


Gray means > 90 MPa



CenterStack  
About 39% of Ip

JT  
STEP=6  
SUB =1  
TIME=.007

```
90189
.689E+07
.137E+08
.205E+08
.273E+08
.341E+08
.409E+08
.477E+08
.545E+08
.613E+08
```




VECTOR  
STEP=8  
SUB =1  
TIME=100.008  
JT  
ELEM=133213  
MIN=3854  
MAX=-.400E+08

```
3854 .445E+07 .890E+07 .133E+08 .178E+08 .222E+08 .267E+08 .311E+08 .356E+08 .400E+08
```

Vessel Outer Region - About 33% of Ip

39%+33%+24%= 96% of Ip



Lower and Upper Passive Plates -  
About 12% Each

```
TIME=100.007
JT
471.439
.519E+08
.104E+09
.156E+09
.208E+09
.259E+09
.311E+09
.363E+09
.415E+09
.467E+09
```



WBS 1.1.1 Disruption  
Analysis of Passive  
Plates, Vacuum Vessel &  
Components  
NSTXU-CALC-12-01-01  
Rev 1 April, 2011  
Prepared By: Peter  
Titus, Contributing  
Authors: A. Brooks,  
Srinivas Avasarala,  
J. Boales Reviewed By:  
Yu Hu Zhai, Cognizant  
Engineer: Peter Titus

# Other Disruption Analyses

**NSTX HHFW (High Harmonic Fast Wave) Eddy Current Analysis for Antenna**  
**NSTX-CALC-24-03-00 Jan 10, 2011 Prepared By:**  
**Han Zhang, Robert Ellis Reviewed By: Ron Hatcher**  
**Cognizant Engineer: Peter Titus,**


**ARMOR BACKING PLATE, NSTX-CALC-24-02-00**

**Prepared by: Larry Bryant, Reviewed by Irv Zatz, Pete Titus,**  
**Cognizant Engineer: Craig Prinski**



**NSTX**


Transient Dynamic  
 Von Mises Stress  
 (Vertical Disruption)



ARMOR PLATE  
 5/07/10  
 L. Bryant

The Transient Equivalent Stress at Max Current is less than 10 Ksi and well within the material strength capacity (Based on Merged Solids)

**WBS 1.2.3 NSTXU Diagnostics Review and Database NSTXU-CALC-40-01-00 September 2010**  
**Prepared By: Joe Boales,**  
**Reviewed By: Yuhu Zhai, NSTX**  
**Cognizant Engineer Bob Kiata**



## Addition of Moment Influence Coefficients to DCPS

**PF1,2,3 supports, welds bolts – At this stage, These are just calculated from influence coefficient matrix loads divided by weld or bolt area. Proposing to add Moment Influence Coefficients**

**PF 4/5 support weldment (see example)  
PF4/5 Conductor (Titus)**

**OH Preload-Launch-TF temperature dependence**


**PF1a-OH interaction Stress**

**Vertical Loads on pedestal load path (TF Flag Bolts, Pedestal hilti's), (Ali)**


**TF Strap (T. Willard)**

**– Mostly designed to TF max Current.  
DCPS should trip if vertical field exceeds limit (.24T?)**

**-More – As a Guide on Scope: Use the number of calculations each with a few sensitive areas**



**Hoop Stress in PF1b**



**Bolt Loads are calculated from the vertical force and the moment divided by the width of the bolt pattern**

**WBS 1.5.2 Upgrade Moment Influence Coefficients  
NSTXU-CALC-13-05-00 January 18 2011**

**Prepared By: Peter Titus,**

**Reviewed By: R. Woolley, Ron Hatcher, NSTX Cognizant Engineer**





# The Bus Bars See Complicated Lorentz Loads and Thermal Loads, PF1a,b Move Upward with the Expansion of the Centerstack

*WBS 1.5.5 Structural Analysis of PF1, TF & OH Bus Bars  
NSTX-CALC-55-01 Prepared By: Andrei Khodak  
Reviewed by Peter Titus Cognizant Engineer: Mark Smith*

ELEMENT SOLUTION

STEP=2  
SUB =1  
TIME=2  
SINT (NOAVG)  
IMX =.021874  
SMN =25482.6  
SMX =.549E+10

PF1B upper Bus Bar Tresca Stress [Pa]



**Centerstack Casing Vertical Displacement From:**

**WBS 1.1.1 Plasma Facing Components,  
Global Thermal Analysis of Center Stack –  
Heat Balance NSTX-CALC-11-01-00  
Prepared By: Art Brooks, Reviewed by:  
Han Zhang, Cognizant Engineer: Jim  
Chrzanowski**



# Needing Resolution:

*PF4/5 coil/support calculation concluded a stiffer PF4/5 column needed. Updated column design needs to be incorporated into the calculation.*

*Slow VDE loading on passive plates needs design to accept large loads or analysis to show they are not needed*

*TF Clamp – No leg brace is needed. Calculations must confirm interim conclusion.*

*Fatigue Data for CTD 101K at 100C is needed.*

*Highly Localized Temperatures in the TF reach 113 degrees C – Test Result look good for 100C- Do we need another test? Or can we back-off slightly on  $i^2 T$ ? – Or accept as-is with slight potential for creep.*

*Centerstack Casing Loads and Stresses for Halo Strikes other than Mid-Plane, Inductive Currents due to P1-P2*

*DCPS Input and Testing.*

*Upper Spoked Lid OD Fixed Connection vs. Pinned*

*PF1a,b Upper Leads to Allow Vertical Motion, Flex of the bus, AND Radial Thermal Growth of the PF's*

*The OH Conductor Must have Manufacturing In-Process NDE to Meet Allowables  
Gary Voss has Provided Luvata Eddy Current Information – We are Evaluating whether Volumetric Inspection is Needed.*

# Back-Up

**From the NSTX Criteria:**

**AISC Table 1.17.5 , AWS Table 5.8, page 194**

**For welds in steel, the design Tresca stress shall be the lesser of:**  
***2/3 of the minimum specified yield if the weld at temperature,***  
***or***  
***1/3 of the minimum specified tensile strength of the weld at temperature.***

Material thickness of thicker part joined (inches)	Minimum size of fillet weld (inches)	Material thickness of thicker part joined (inches)	Minimum size of fillet weld (inches)
To ¼ inch inclusive	1/8	over 1.5 to 2.5	3/8
Over ¼ to ½ in.	3/16	Over 2.25 to 6	1/2
Over ½ to ¾ in.	¼	Over 6	5/8
Over ¾ to 1.5 in.	5/16		

**From the AISC Criteria:**

Reference and Weld	Rod or weld wire	Parent Material	Allowable Stress (Exclusive of Weld Efficiency)
AISC Stress on cross section of full penetration Welds	-Peter	All	Same as Base material
AISC Shear Stress on Effective Throat of fillet weld	AWS A5.1 E60XX	A36 -	21 ksi

***For shear on an effective throat of a fillet, For 304 Stainless, the weld metal is annealed, or the base metal in the heat effected zone is annealed. and Estimate  $241 * 21/36 = 140 \text{ MPa} = 20 \text{ ksi (without weld efficiency)}$***   
***This is consistent with NSTX Criteria of 2/3 yield or 2/3 of 30ksi for annealed 304***  
***With a weld efficiency of .7 the allowable is 14ksi, or 96 MPa***  
***For fillets divide weld area by sqrt(2)***

## Criteria – Allowables for Coil Copper Stresses

The TF copper ultimate is 39,000 psi or 270 MPa . The yield is 38ksi (262 MPa).  $S_m$  is 2/3 yield or 25.3ksi or 173 MPa – for adequate ductility, which is the case with this copper which has a minimum of 24% elongation. Note that the 1/2 ultimate is not invoked for the conductor (It is for other structural materials) . These stresses should be further reduced to consider the effects of operation at 100C. This effect is estimated to be 10% so the  $S_m$  value is **156 MPa**.

- From: I-4.1.1 Design Tresca Stress Values ( $S_m$ ), NSTX\_DesCrit\_IZ\_080103.doc
- • (a) For conventional (i.e., non-superconducting) conductor materials, the design Tresca stress values ( $S_m$ ) shall be 2/3 of the specified minimum yield strength at temperature, for materials where sufficient ductility is demonstrated (see Section I-4.1.2). \*
- It is expected that the CS would be a similar hardness to the TF so that it could be wound readily. For the stress gradient in a solenoid, the bending allowable is used. The bending allowable is **1.5\*156 or 233MPa**,



# NSTX Fatigue Criteria Document:

A fatigue strength evaluation is required for those NSTX CSU components with undetectable flaws that are either cycled over 10,000 times or are exposed to cyclic peak stresses exceeding yield stress.

## NSTX GRD:

*For engineering purposes, number of NSTX pulses, after implementing the Center Stack Upgrade, shall be assumed to consist of a total of ~ 60,000 pulses based on the GRD specified pulse spectrum.*


## Aged Components:

*NSTX Components Have Been Aged (Maybe the cause of the present OH terminal failure)*

*• Because of the increase in loads, Minors Rule and Non-Linearity of Fatigue, Previous Stress Cycles Will Add Little. The Criteria document includes guidance on how to treat this, but:*


- The primary means of qualification for fatigue will be in-service inspection.*
- The Upgrade will have what is essentially a pre-service inspection.*
- Develop an Inspection regimen based on visual screening and penetrant tests of suspect areas.*
- Use the DCPS for cycle counting and Minors rule usage*

*NSTXBo x NSTXIp  
NSTX-UBo x NSTX-UIp*




# CS Structural/Emag Modeling

A. Zolfaghari




SEQV (AVG)  
DMX = .001001  
SMN = 269846  
SMX = .647E+08



Hot OH, Cold TF, OH Self EM Load

No currents, Cold TF, Cold OH

Bellville stack, 18 mm preload and 2.5e7 N/m spring constant



TF Temp.	OH Temp.	TF Current	OH Current	Launch Force	Peak OH Stress	Peak TF Stress	Peak Displacement	OH Lifted?	Case #	Notes
COLD	COLD	OFF	OFF	OFF	7-14 MPA	7-14 MPA	0.6 mm TF	NO	00000	Bellville staff force only
HOT	COLD	ON	OFF	OFF	102-115 MPA	38-51 MPA	8.8 mm TF	NO	10100	TF grows pushing OH laterally
COLD	HOT	OFF	OFF	OFF	10-19 MPA	19-29 MPA	4.6 mm OH	NO	01000	
COLD	HOT	OFF	ON	OFF	125-140 MPA	16-31 MPA	1.6 mm OH	NO	01010	TF was off and OH current was turned on with hoop stress only
COLD	HOT	OFF	ON	ON	123-138 MPA	16-31 MPA	1.9 mm OH	NO	01011	TF was off and OH current was turned on with hoop stress and launch force.
HOT	COLD	ON	ON	ON	117-132 MPA	15-29 MPA	8.2 mm TF	NO	10111	Just in case, OH getting current before heating up
HOT	HOT	ON	ON	ON	110-134 MPA	15-19 MPA	8.3 mm	NO	11111	

# Insulation Shear Stress Allowable

From NSTX TF Test Report:

## Planned VPI CTD 101K

- From Dick Reed Reports/Conversations:
- Shear strength, short-beam-shear, interlaminar
  - Without Kapton (TF, PF1 a,b,c) **65 MPa**
  - With Kapton **40 MPa (CS)**
  - Estimated Strength at Copper Bond = **65 MPa/2 = 32.5 MPa (All Coils)**
- From Criteria Document:
- I-5.2.1.3 Shear Stress Allowable**
- The shear-stress allowable,  $S_s$ , for an insulating material is most strongly a function of the particular material and processing method chosen, the loading conditions, the temperature, and the radiation exposure level. The shear strength of insulating materials depends strongly on the applied compressive stress. Therefore, the following conditions must be met for either static or fatigue conditions:

$$S_s = [2/3 \text{ to } ] + [c_2 \times S_c(n)]$$


$$2/3 \text{ of } 32.5 \text{ MPa} = 21.7 \text{ MPa}$$

$$5 \text{ ksi} = 34 \text{ MPa}$$

$$2/3 \text{ of this is } 23 \text{ MPa}$$

$$C_2 = .1 \text{ (not .3)}$$

## Existing TF Prepreg CTD 12P




$$2/3 \text{ of } 24 = 16 \text{ MPa (Static)}$$

C2 ~ .44

Should be Further De-rated for Fatigue

From an October 27 2009 email from Dick Reed



# AWS Criteria

- AWS states that it does not apply to pressure vessels. Our drawings of the vessel call out ASME B31.3 category D This is a non-hazardous piping code. Given that most of the weldments that we are evaluating are non-standard arrangements that neither fit the vessel code, or piping code, AWS would be an OK call-out
- AWS prefaces the Design section by stating that the sizing should be as specified in the contract – or the "Engineer" regarding requirements.
- Inspection is one area where the requirements are to be outlined in contract documents or in design specifications or drawings. Although the design guidance is clearly recommending inspection for fatigue applications.
- Table 2.3 (page24) gives allowable stresses in welds. The tension and compression stress limit for full penetration welds is the base metal strength. NSTX is using annealed properties of base metal.
- The stress limit for fillets is based on shear in the net section (consistent with ASME, and AISC)
- The allowable is based on 0.3\* tensile strength of the filler metal or .4\* the yield strength of the base metal. There are some notes that will require some interpretation, but it is consistent with AISC, and ASME.
- Guidance regarding weld efficiencies for specific inspection procedures is not included, but the code would not override guidance from the "Engineer" that chose to apply them.

## •AWS has a lot of useful fatigue design guidance for welds.

*It has of calculation guidance and local weld design, and surface contour guidance to mitigate the effects of fatigue. Inspection of welds subject to fatigue is required (paragraph 2.18 which requires RT or UT). Mag Particle (MT) is also mentioned in the fatigue sections. Inspection methods are described in section 6 which includes a note allowing penetrant (PT) inspection, but the code appears to prefer radiographic or ultrasonic inspection.*

Table 2.4 (Continued)

Description	Stress Category	Constant $C_r$	Threshold $F_{TH}$ ksi [MPa]	Potential Crack Initiation Point	Illustrative Examples
<b>Section 3—Welded Joints Joining Components of Built-Up Members</b>					
3.1 Base metal and weld metal in members without attachments built-up or plates or shapes connected by continuous longitudinal CJP groove welds, backgouged and welded from second side, or by continuous fillet welds.	B	$120 \times 10^3$	16 [110]	From surface or internal discontinuities in weld away from end of weld	
3.2 Base metal and weld metal in members without attachments built-up or plates or shapes connected by continuous longitudinal CJP groove welds with backing not removed, or by continuous FJP groove welds.	B'	$61 \times 10^3$	12 [83]	From surface or internal discontinuities in weld, including weld attaching backing	
3.3 Base metal and weld metal at termination of longitudinal fillet at weld access holes in built-up members.	D	$22 \times 10^3$	7 [48]	From the weld termination into the web or flange	
3.4 Base metal at ends of longitudinal intermittent fillet weld segments.	E	$11 \times 10^3$	4.5 [31]	In connected material at start and stop locations of any weld deposit	